



eurofins

# Attestation

Eurofins Product Testing A/S received a sample of a varnish with the name

## **LOBA WS 2K Supra LOBA GmbH & Co. KG**

The emissions were tested in the style of the method "Testing of volatile organic emissions from various sources using small-scale environmental chambers" as defined in the California Specification Section 01350 (CA/DHS/EHLB/R-174) - Version of July 15, 2004, see test report no. 765492rev.

**Testing was already performed after 10 days.**

### **Evaluation of the test result according to CA 01350 guidelines:**

---

- No carcinogens and reproductive/developmental toxins could be detected.
  - No individual VOC exceeds one-half of the lowest concentration of interest in a building (chronic REL).
  - Formaldehyde concentration does not exceed one-half of the lowest concentration of interest in a building (indoor REL).
- 

**The tested product complies with the requirements of California Specification Section 01350 (CA/DHS/EHLB/R-174) - Version of July 15, 2004 when tested after 10 days.**

19 March 2010

---

Thomas Neuhaus  
Head of product emission test centre

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK-8464 Galten / Denmark

Tel +45 70 22 42 76  
Fax +45 70 22 42 75